

<p>NOTE: IF ROOF DRAIN DOES NOT DRAIN TO PARKING/DRIVE SURFACE, THEN CONDENSATE TO DRAIN TO ROOF DRAIN. IF ROOF DRAINS TO PARKING/DRIVE SURFACE, THEN CONDENSATE TO DRAIN TO FLOOR SINK INSIDE STORE.</p> <p>MIN. TRAP DEPTH 4". CENTERLINE OUTLET TO CENTERLINE DRAIN 1/2" PLUS UNIT TOTAL STATIC PRESSURE AS A MINIMUM. DISTANCE FROM OUTLET TO TRAP NOT LESS THAN 2 PIPE DIAMETERS.</p> <p>THREADED PIPE ADAPTER ON CONDENSATE DRAIN CONNECTION</p> <p>PROVIDE UNION ON EACH SIDE OF TRAP.</p> <p>VENT OPEN TO ATMOSPHERE.</p> <p>CONT. ON MECH. ROOF PLAN, SHEET M-100</p> <p>CL TO CL = MIN. 1/2" + TOTAL STATIC PRESSURE OF UNIT.</p> <p>SEE DETAIL 1P-500</p> <p>4" DEEP PIPE TRAP</p> <p>RTU</p> <p>EQUIPMENT CURB</p> <p>TYPICAL ROOFTOP AIR-CONDITIONING UNIT</p> <p>NOTE:</p> <ol style="list-style-type: none">1. PIPING ARRANGEMENT SHOWN IS SCHEMATIC. ADJUST AS REQUIRED. VERIFY CONNECTION LOCATIONS BEFORE INSTALLING PIPE RUNS. DO NOT PROVIDE TRAP ON UNITS WHICH HAVE AN INTERNAL TRAP.2. DRAIN LINES TO BE TYPE L COPPER.3. FOR BLOW-THROUGH TYPE EQUIPMENT, ADJUST PTRAP DEPTH TO 1/2" PLUS TOTAL STATIC PRESSURE OF UNIT.		19	A.C. UNIT CONDENSATE DRAIN		16																																											
NOT USED		Scale: NO SCALE	P-500	Scale: NO SCALE		P-500																																										
<p>PROVIDED & INSTALLED BY CONTRACTOR</p> <p>PROVIDE & INSTALLED BY VENDOR</p> <p>PROVIDE & INSTALLED BY OWNER</p> <p>PROVIDE & INSTALLED BY VENDOR</p> <p>PROVIDED & INSTALLED BY CONTRACTOR</p> <p>1" IN CLG WITHIN CLOSE PROXIMITY TO B.I.B. BELOW</p> <p>FLOW</p> <p>TO DINING</p> <p>TO DRIVE-THRU</p> <p>TO VENDOR PROVIDED EQUIPMENT</p> <p>COKE MANIFOLD BY VENDOR</p> <p>NO COPPER THIS SIDE</p> <p>COPPER THIS SIDE</p> <p>FROM MANIFOLD PORT C3</p> <p>S.S. RPZ</p> <p>TEST PORT/ ATMOSPHERIC VALVE</p> <p>BARBED FITTING</p> <p>ROUTE TO HUB DRAIN. REFER PLUMBING PLAN FOR LOCATION</p> <p>NOTE:</p> <ol style="list-style-type: none">1. CONTRACTOR TO COORDINATE WITH PANDA PROJECT MANAGER ON EXACT CONFIGURATION PRIOR TO CONSTRUCTION																																																
		BAG-N-BOX DETAIL				15																																										
		Scale: NO SCALE				P-500																																										
<p>PROVIDE ROUND SECURED NICKEL BRONZE ADJUSTABLE TOP WITH "CO" CAST IN COVER. PROVIDE CLEANOUT TOP WITH VARIATIONS SUITABLE FOR FLOOR COVERING (CARPET MARKER, RECESSED FOR TILE, SCORATED FOR UNFINISHED FLOORS). PROVIDE PLASTIC PLUG IN CAST IRON BODY. CLEAN THE TOP OF EXPOSED FOO AFTER INSTALLATION.</p> <p>MEMBRANE CLAMP</p> <p>AS REQUIRED FOR DEPTH OF SEWER</p> <p>WASTE PIPE BELOW FLOOR.</p> <p>SANITARY OR STORM SEWER LINE</p> <p>LONG SWEEP ELBOW AT END OR TURN OF RUN</p> <p>COMBINATION WYE AND EIGHTH BEND IN RUN ENTER TOP OF PIPE.</p> <p>DIRECTION OF FLOW</p> <p>TWO-WAY CLEANOUT FOR LOCATION, SEE DWG P-101</p> <p>FLOOR SLAB ON GRADE</p> <p>SAME SIZE AS SEWER UP TO 4" MAXIMUM.</p> <p>NOTE:</p> <ol style="list-style-type: none">1. LOCATE AT BUILDING EXIT, AT ENDS OF RUNS, AT TURNS OF PIPE GREATER THAN 45 DEGREES, AT 50' INTERVALS ON STRAIGHT RUNS, AND WHERE SHOWN ON PLANS.2. PROVIDE BACKFILL PER ARCHITECTURAL SPECIFICATIONS.3. LOCATE CLEANOUTS WHERE THERE IS 18" CLEAR AROUND.4. CONSULT LOCAL CODES FOR OTHER FOO REQUIREMENTS.																																																
		FLOOR CLEANOUT				11																																										
		Scale: NO SCALE				P-500																																										
<p>OTHER VENTING METHODS MAY BE USED IF APPROVED BY LOCAL CODE.</p> <p>CONCRETE FLOOR SLAB W/ 1/2" TILE ON TOP OF DRAIN FLUSH WITH TILE</p> <p>REDUCING TRAP</p> <p>MEMBRANE CLAMP. ING COLLAR AND SEEPAGE PAN. MAXIMUM TAILPIECE LENGTH IS 2 FEET.</p> <p>SLOPE WASTE AT TWO PERCENT.</p> <p>MAXIMUM 5' ON 2" WASTE OR 6' ON 3".</p> <p>PROVIDE TRAP PRIMER</p> <p>MAXIMUM 15' WHERE ENLARGED WASTE LINE IS USED AS A COMBINATION WASTE AND VENT SYSTEM.</p> <p>NOTE:</p> <ol style="list-style-type: none">1. LOCATE FLOOR DRAIN/SINK WHERE SHOWN ON DIMENSIONED ARCHITECTURAL PLAN. IF FLOOR STRUCTURE INTERFERES WITH FLOOR SINK, MOVE SIDWAYS IF POSSIBLE. OTHERWISE MOVE BACK. ALWAYS LOCATE WHERE EASILY ACCESSIBLE, BUT NOT IN FOOT TRAFFIC.2. IF SITUATION IS FLOOR SLAB ON GRADE, PROVIDE BACKFILL PER SPECIFICATIONS. IF CONCRETE FLOOR IS NOT EXISTING, SET DRAIN IN PLACE AND POUR AROUND IT. OR BLOCK OUT AND POUR IN LATER.3. IF CONCRETE FLOOR IS EXISTING, SAW CUT OR CORE DRILL IT. SET DRAIN BODY IN PLACE AND POUR AROUND IT.4. TOP OF THE FLOOR SINK / DRAIN SHOULD BE SET AT THE SAME ELEVATION AS THE SLAB AND THEN DISHED OUT 1/2" AT THE DRAIN SLOPING TO NOTHING AT THE 2" RADIUS POINT.5. IF SITUATION IS FLOOR NOT ON GRADE, REFER TO "FLOOR PENETRATION" DETAIL FOR VENTS.6. PROVIDE TRAP PRIMER FOR FLOOR DRAINS IN RESTROOMS.																																																
		FLOOR DRAIN/SINK				8																																										
		Scale: NO SCALE				P-500																																										
<p>SHOWN ON PLAN, 6". FOAM SEAL BOTH ENDS. USE 135" LONG SWEEP ELBOWS.</p> <p>SEAL TO CABINET WITH SILICONE.</p> <p>LENGTH AS REQUIRED</p> <p>DETAIL</p> <p>SODA CONDUIT STUBS, TYP. (2)</p> <p>SODA SHELF PARTITION WALL</p> <p>RAISED CONC. PEDESTAL REF. ARCH.</p> <p>PLAN VIEW</p> <p>NOTE:</p> <ol style="list-style-type: none">1. USE SIX INCH PVC FITTINGS AND COUPLINGS.2. USE MINIMUM QUANTITY OF COUPLINGS REQUIRED.3. USE LONG SWEEP ELBOWS AT BOTH ENDS. MINIMUM TWENTY FOUR INCH RADIUS.4. AVOID ELBOWS IN HORIZONTAL RUN IF AT ALL POSSIBLE.5. DO NOT USE 45° ELBOWS.																																																
		BELOW-GROUND SODA CONDUIT				4																																										
		Scale: NO SCALE				P-500																																										
<p>2" VENT IN WALL</p> <p>CLEANOUT</p> <p>4" GREASE WASTE</p> <p>2" COPPER PIPE</p> <p>LOCATION OF CHEMICAL SYSTEM</p> <p>THREE COMPARTMENT SINK</p> <p>UNION CONNECTION</p> <p>NOTE:</p> <ol style="list-style-type: none">1. ARRANGEMENT SHOWN IS SCHEMATIC. ADJUST TO SUIT FIELD CONDITIONS OR MEET LOCAL CODE REQUIREMENTS.2. PROVIDE COPPER PIPE, FITTINGS AND CONNECTORS ALL AROUND SINK AND TRAP.																																																
		UTILITY/SINK				7																																										
		Scale: NO SCALE				P-500																																										
<p>BY GAS COMPANY (VERIFY) BY PLUMBING CONTRACTOR</p> <p>PRESSURE TEST COCK</p> <p>GAS METER OF CFH CAPACITY SHOWN ON PLANS</p> <p>STRAINER (OPTIONAL)</p> <p>EXTERIOR BUILDING WALL</p> <p>FURRED INTERIOR WALL</p> <p>GAS PIPE UP. SIZE AS SHOWN ON PLAN. USE BLACK STEEL PIPE.</p> <p>PIPE INCREASER.</p> <p>DIRT LEG AT BOTTOM OF RISER.</p> <p>ANCHOR RISER TO WALL.</p> <p>DIRT LEG ACCESS PANNEL</p> <p>GRADE OR PAVEMENT</p> <p>FLOOR</p> <p>PRESSURE REGULATOR TO REDUCE PRESSURE TO 7" WC.</p> <p>SHUT-OFF VALVE</p> <p>NOTE:</p> <ol style="list-style-type: none">1. VERIFY REQUIREMENTS FOR METERING AND PIPING WITH GAS COMPANY.2. INSTALL OTHER UTILITIES MINIMUM TEN FEET FROM GAS LINE.3. PLUMBING CONTRACTOR SHALL PAY ALL GAS COMPANY FEES FOR INSTALLATION.4. USE WELDED OR SCREWED PIPE AND FITTINGS PER PLUMBING SPECS.5. GAS COMPANY SHALL EXCAVATE, BACKFILL, AND REPAIR ANY PAVING OR SOD FOR GAS SERVICE LINE.6. PAINT EXPOSED METAL GAS PIPE, FITTINGS AND ITEMS SAFETY YELLOW.																																																
		GAS SERVICE				3																																										
		Scale: NO SCALE				P-500																																										
<p>FOODSERVICE EQUIPMENT</p> <p>HOSE & FITTING QUICK DISCONNECT</p> <p>UL LISTED SHUT-OFF VALVE</p> <p>UTILITY INLET</p> <p>COORDINATE WALL REINFORCING WITH GENERAL CONTRACTOR</p> <p>FINISHED FLOOR</p> <p>RESTRAINING CABLE</p> <p>NOTE:</p> <ol style="list-style-type: none">1. IF UTILITY IS NOT AT FULL HEIGHT SHOWN, PROVIDE PIPING WITH ELBOWS TO RAISE INLET																																																
		QUICK DISCONNECT				18																																										
		Scale: NO SCALE				P-500																																										
<p>INSTALL PER PDI STANDARDS AND MANUFACTURER'S INSTRUCTIONS.</p> <p>HOT OR COLD WATER SUPPLY</p> <p>IF HORIZONTAL BRANCH IS LESS THAN 20' LONG, PROVIDE ONE WHA AT END OF LINE. IF BRANCH IS GREATER THAN 20' LONG, PROVIDE ANOTHER WHA IN MIDDLE, EACH SIZED FOR HALF THE FIXTURE UNITS.</p> <p>SINGLE FIXTURE</p> <table><tr><th>PDI SIZE</th><th>PIPE SIZE</th><th>FIXTURE UNIT LOAD</th></tr><tr><td>A</td><td>1/2"</td><td>1-11</td></tr><tr><td>B</td><td>3/4"</td><td>12-32</td></tr><tr><td>C</td><td>1"</td><td>33-60</td></tr><tr><td>D</td><td>1-1/4"</td><td>61-113</td></tr><tr><td>E</td><td>1-1/2"</td><td>114-154</td></tr><tr><td>F</td><td>2"</td><td>154-330</td></tr></table> <p>MULTIPLE FIXTURES</p> <table><tr><th>FIXTURE</th><th>COLD</th><th>HOT</th></tr><tr><td>VALVE WATER CLOSET</td><td>10</td><td>-</td></tr><tr><td>TANK WATER CLOSET</td><td>5</td><td>-</td></tr><tr><td>URINAL</td><td>5</td><td>-</td></tr><tr><td>LAVATORY/SINK</td><td>1.5</td><td>1.5</td></tr><tr><td>JANITOR'S SINK</td><td>3</td><td>3</td></tr><tr><td>SHOWER/BATHTUB</td><td>2</td><td>2</td></tr></table> <p>NOTE:</p> <ol style="list-style-type: none">1. DO NOT PROVIDE AIR CHAMBERS.2. PROVIDE WATER HAMMER ARRESTERS BY SIOUX CHIEF, PRECISION PLUMBING PRODUCTS, WATTS OR APPROVED EQUIVALENT WITH PISTON AND O-RING CONSTRUCTION, HAVING PDI #WH-201, ASSE # 1010 AND ANSI # A112.26.1M CERTIFICATION.3. INSTALL IN HORIZONTAL OR VERTICAL POSITION, BUT NEVER UPSIDE DOWN.4. INSTALL IN LINE WITH WATER FLOW DIRECTION IF POSSIBLE.5. SIZE THE UNITS AS SHOWN ON THE DRAWINGS AND/OR PER THE TABLES SHOWN ABOVE.		PDI SIZE	PIPE SIZE	FIXTURE UNIT LOAD	A	1/2"	1-11	B	3/4"	12-32	C	1"	33-60	D	1-1/4"	61-113	E	1-1/2"	114-154	F	2"	154-330	FIXTURE	COLD	HOT	VALVE WATER CLOSET	10	-	TANK WATER CLOSET	5	-	URINAL	5	-	LAVATORY/SINK	1.5	1.5	JANITOR'S SINK	3	3	SHOWER/BATHTUB	2	2					
PDI SIZE	PIPE SIZE	FIXTURE UNIT LOAD																																														
A	1/2"	1-11																																														
B	3/4"	12-32																																														
C	1"	33-60																																														
D	1-1/4"	61-113																																														
E	1-1/2"	114-154																																														
F	2"	154-330																																														
FIXTURE	COLD	HOT																																														
VALVE WATER CLOSET	10	-																																														
TANK WATER CLOSET	5	-																																														
URINAL	5	-																																														
LAVATORY/SINK	1.5	1.5																																														
JANITOR'S SINK	3	3																																														
SHOWER/BATHTUB	2	2																																														
		WATER HAMMER ARRESTERS				14																																										
		Scale: NO SCALE				P-500																																										
<p>FLUE CAP PER MFR.</p> <p>AIR INTAKE</p> <p>COUNTER FLASHING BY GENERAL CONTRACTOR</p> <p>FLASHING BY GENERAL CONTRACTOR</p> <p>24 GA. SLAVE</p> <p>ROOFING</p> <p>ROOF FRAMING TYPICAL</p> <p>SECURE CLAP BAND TO FRAMING</p> <p>LAY-IN CEILING</p> <p>CLAMP BAND</p> <p>FRAMED ROOF OPENING BY GENERAL CONTRACTOR</p> <p>EXHAUST</p> <p>INTAKE</p> <p>TO WATER HEATER</p> <p>POINTS OF CONNECTION</p> <p>NOTE:</p> <ol style="list-style-type: none">1. PROVIDE WCO WHERE SHOWN ON PLAN. LOCATE ABOVE FIXTURE FLOOD RIM.2. CONSULT LOCAL CODES FOR OTHER WCO REQUIREMENTS.																																																
		CONCENTRIC VENT DETAIL				10																																										
		Scale: NO SCALE				P500																																										
<p>PROVIDE CLEANOUT TEE WITH SCREWED COUNTER-SUNK PLASTIC PLUG: TAPERED-THREAD WITH THE JOINT COMPROMISED.</p> <p>WHERE CLEANOUT TEE IS CONCEALED IN A CHASE OR PARTITION, PROVIDE A ROUND 18 GAUGE STAINLESS STEEL COVER WITH BEVELED EDGES AND FLATHEAD MACHINE SCREW.</p> <p>COLUMN OR PARTITION AS SHOWN ON FLOOR PLAN.</p> <p>CLEANOUT FACE SHALL BE WITHIN 4" OF WALL SURFACE. PROVIDE PIPE EXTENSION IF REQUIRED.</p> <p>CONCRETE FLOOR SLAB</p> <p>REFER TO PLUMBING FIXTURE SCHEDULE FOR FURTHER INFORMATION.</p> <p>NOTE:</p> <ol style="list-style-type: none">1. PROVIDE WCO WHERE SHOWN ON PLAN. LOCATE ABOVE FIXTURE FLOOD RIM.2. CONSULT LOCAL CODES FOR OTHER WCO REQUIREMENTS.																																																
		WALL CLEANOUT				6																																										
		Scale: NO SCALE				P-500																																										
<p>DRILL HOLE IN SIDE OF BOX AND PROVIDE SILICONE SEAL AROUND PIPE PENETRATION.</p> <p>3/4"</p> <p>DX COIL</p> <p>CO</p> <p>COORDINATE ROUTING OF DRAIN WITH SHELVEING IN WALK-IN BOX</p> <p>PROVIDE 1" ELASTOMERIC INSULATION OVER HEAT TRACING ON CONDENSATE LINE (FOR FREEZER BOX ONLY) BY WALK IN BOX INSTALLER. (ELECTRIC HEATING CABLE IS BY CONTRACTOR).</p> <p>PROVIDE CLEANOUT IN TURNS AND ENDS OF PIPE</p> <p>MAKE CONNECTION TO COIL AS REQUIRED</p> <p>WALK-IN COOLER OR FREEZER BOX</p> <p>SEE FLOOR PLAN FOR RECEPTACLE LOCATION.</p> <p>NOTE:</p> <ol style="list-style-type: none">1. INSTALL PIPE A MINIMUM OF 76" ABOVE FINISH FLOOR, ANCHORED TO WALL OF BOX WITH SUPPORTS AT MAXIMUM SIX FOOT CENTERS.2. USE TYPE "M" HARD COPPER TUBE AND FITTINGS WITH LEAD-FREE SOLDER JOINTS.3. SLOPE HORIZONTAL PIPE AT MINIMUM TWO PERCENT.4. KEEP DRAIN LINE FROM EVAPORATOR AS HIGH AS POSSIBLE UNDER THE EVAPORATOR BACK TO THE WALL TO MAXIMIZE SHELVE SPACE UNDER THE COIL.5. REFER TO LOCAL CODE FOR INDIRECT DRAIN REQUIREMENTS.6. INDIVIDUAL CONDENSATE LINES FROM EACH EVAPORATOR TO BE 3/2" UNTIL JOINED. CONDENSATE LINE TO BE 1" AFTER UNION.																																																
		WALK - IN BOX CONDENSATE DRAIN				2																																										
		Scale: NO SCALE				P-500																																										
<p>OVERHEAD C.W. SUPPLY</p> <p>TRAP PRIMER</p> <p>LAY-IN CEILING</p> <p>UNION</p> <p>VACUUM BREAKER</p> <p>FINISH FLOOR</p> <p>GRAVITY LINE TO TRAP</p> <p>NOTE:</p> <ol style="list-style-type: none">1. PROVIDE 12" FIBERGLASS INSULATION WITH ALL-SERVICE JACKET WITH VAPOR BARRIER OR APPROVED EQUAL ON ALL COLD WATER, CONDENSATE, AND STORM DRAIN PIPE UP TO 4".2. PROVIDE 1" INSULATION OR APPROVED EQUAL ON STORM DRAIN PIPE ABOVE 4" SIZE.3. PROVIDE 1" FIBERGLASS INSULATION WITH ALL-SERVICE JACKET OR APPROVED EQUAL ON DOMESTIC HOT WATER PIPING.4. REFER TO SPECIFICATIONS FOR FURTHER INFORMATION REGARDING INSULATION. INSTALL ALL ITEMS PER SPECIFICATIONS AND MANUFACTURER'S INSTRUCTIONS.5. MAINTAIN VAPOR BARRIER ON COLD PIPING BY MEANS OF SEALANT AND TAPE.6. FLAME SPREAD AND SMOKE DEVELOPED INDEXES SHALL NOT EXCEED 25/50.7. SEAL EXPOSED ENDS OF FIBERGLASS INSULATION WITH ADHESIVE MASTIC.																																																
		PREP. AREA TRAP PRIMER DETAIL				17																																										
		Scale: NO SCALE				P-500																																										
<p>COVER VALVE BODIES WITH INSULATION, BUT NOT UNIONS.</p> <p>NOTE: MITER THE INSULATION AT TEES AND ELBOWS SO THAT THERE ARE NO GAPS AT JOINTS IF POSSIBLE, THEN TAPE THEM. OTHERWISE FILL THE GAPS WITH BLANKET FIBERGLASS MOULDED PVC FITTING COVERS</p> <p>PROVIDE 12" UNICELLULAR ELASTOMERIC INSULATION OR APPROVED EQUAL ON DOMESTIC HOT AND COLD WATER PIPES AND ALL CEILING SPACES IN WALLS AND CHASES. MITER THE INSULATION AT TEES AND ELBOWS. SEAL ALL JOINTS WITH ADHESIVE</p> <p>REFER TO OTHER DETAILS FOR TREATMENT OF INSULATION AT PENETRATION OF WALLS, FLOORS, AND FIREWALLS</p> <p>NOTE:</p> <ol style="list-style-type: none">1. PROVIDE 12" FIBERGLASS INSULATION WITH ALL-SERVICE JACKET WITH VAPOR BARRIER OR APPROVED EQUAL ON ALL COLD WATER, CONDENSATE, AND STORM DRAIN PIPE UP TO 4".2. PROVIDE 1" INSULATION OR APPROVED EQUAL ON STORM DRAIN PIPE ABOVE 4" SIZE.3. PROVIDE 1" FIBERGLASS INSULATION WITH ALL-SERVICE JACKET OR APPROVED EQUAL ON DOMESTIC HOT WATER PIPING.4. REFER TO SPECIFICATIONS FOR FURTHER INFORMATION REGARDING INSULATION. INSTALL ALL ITEMS PER SPECIFICATIONS AND MANUFACTURER'S INSTRUCTIONS.5. MAINTAIN VAPOR BARRIER ON COLD PIPING BY MEANS OF SEALANT AND TAPE.6. FLAME SPREAD AND SMOKE DEVELOPED INDEXES SHALL NOT EXCEED 25/50.7. SEAL EXPOSED ENDS OF FIBERGLASS INSULATION WITH ADHESIVE MASTIC.																																																
		PIPE INSULATION				13																																										
		Scale: NO SCALE				P-500																																										
<p>LAVATORY</p> <p>UNION</p> <p>1/2" CW FROM TAILPIECE, DN. IN WALL & OVER BELOW FLOOR TO FLOOR DRAIN</p> <p>FLOOR DRAIN</p> <p>FINISH FLOOR</p> <p>GRAVITY LINE TO TRAP</p> <p>SIOUX CHIEF "TRAP-EASE" MODEL 200-090 TRAP PRIMER TAILPIECE</p> <p>NOTE:</p> <ol style="list-style-type: none">1. PROVIDE 12" FIBERGLASS INSULATION WITH ALL-SERVICE JACKET WITH VAPOR BARRIER OR APPROVED EQUAL ON ALL COLD WATER, CONDENSATE, AND STORM DRAIN PIPE UP TO 4".2. PROVIDE 1" INSULATION OR APPROVED EQUAL ON STORM DRAIN PIPE ABOVE 4" SIZE.3. PROVIDE 1" FIBERGLASS INSULATION WITH ALL-SERVICE JACKET OR APPROVED EQUAL ON DOMESTIC HOT WATER PIPING.4. REFER TO SPECIFICATIONS FOR FURTHER INFORMATION REGARDING INSULATION. INSTALL ALL ITEMS PER SPECIFICATIONS AND MANUFACTURER'S INSTRUCTIONS.5. MAINTAIN VAPOR BARRIER ON COLD PIPING BY MEANS OF SEALANT AND TAPE.6. FLAME SPREAD AND SMOKE DEVELOPED INDEXES SHALL NOT EXCEED 25/50.7. SEAL EXPOSED ENDS OF FIBERGLASS INSULATION WITH ADHESIVE MASTIC.																																																
		RESTROOM TRAP PRIMER DETAIL				9																																										
		Scale: NO SCALE				P-500																																										
<p>STEPPED FLEXIBLE PVC OR NEOPRENE COUPLING CLAMPED TO FLASHING AND PIPE WITH STAINLESS STEEL SCREW CLAMPS.</p> <p>RIGHT AND LEFT NIPPLE & COUPLINGS 1998 CPC SEE #1211.10</p> <p>ELBOWS TO COMPENSATE FOR PIPE EXPANSION</p> <p>REFER TO DETAIL</p> <p>PROVIDE ROOFING BOOT COORDINATE WITH ROOFER</p> <p>ROOFING OVER METAL FLASHING BY ROOFING CONTRACTOR</p> <p>ROOF INSULATION</p> <p>ROOF DECK</p> <p>SLEEVE ROOF IF REQUIRED</p> <p>ANCHOR PIPE TO ROOF DECK OR JOISTS</p> <p>NOTE:</p> <ol style="list-style-type: none">1. REFER TO PLANS FOR PIPE SIZE(S) AND LOCATION(S).2. WELDED OR SCREWED FITTINGS AS SPECIFIED FOR PIPE SIZE.3. LOCATE PENETRATION MINIMUM 18" FROM ADJACENT WALLS.																																																
		GAS PIPE ROOF PENETRATION				5																																										
		Scale: NO SCALE				P-500																																										
<p>GALVANIZED STEEL CLAMP. DO NOT CLAMP PIPE TIGHT.</p> <p>ERICO RPS50H6 PIPE SUPPORT AND DETAIL INSTALLATION SEE WWW.ERICO.COM</p> <p>ROOFING</p> <p>ROOF INSULATION</p> <p>ROOF DECK</p> <p>NOTE:</p> <ol style="list-style-type: none">1. LOCATE AT TURNS OF PIPE, AT 4' SPACING FOR PLASTIC PIPE, AND AT THIS SPACING FOR METAL PIPE: 5"x16" 4"x14" 3"x12" 2-1/2"x11" 2"x10" 1-1/2"x9" 1-1/4"x8" 1"x7" 3/4"x6". PLACE BASE SHEETS ON ROOFING BEFORE GRAVEL IF ANY. SET BLOCKS FREE ON BASE SHEETS. STACK BLOCKS AND NAIL THEM TOGETHER WHERE REQUIRED TO ELVATE PIPING.2. PRIMER COAT AND PAINT EXTERIOR GAS PIPE SAFETY YELLOW COLOR.3. 18"x18"x1/2" THICK ROOF WALKWAY MATERIAL FOR BASE SHEET. ("CAREY-TRED" OR PER ARCHITECTURAL SPECIFICATIONS.)																																																
		ROOF PIPE SUPPORT				1																																										
		Scale: NO SCALE				P-500																																										



PANDA RESTAURANT GROUP INC.
1683 Walnut Grove Ave.
Rosemead, California
91770
Telephone: 626.799.9898
Facsimile: 626.372.8288

All ideas, designs, arrangement and plans indicated or represented by this drawing are the property of Panda Express Inc. and were created for use on this specific project. None of these ideas, designs, arrangements or plans may be used by or disclosed to any person, firm, or corporation without the written permission of Panda Express Inc.

REVISIONS:

ISSUE DATE:

1 03.04.2022 ISSUE FOR PERMIT

DRAWN BY: SDT

PANDA PROJECT # - S8-22-D8698
C&P PROJECT # - 2210806

CUHACI PETERSON

2600 Maitland Center Parkway
Suite #200
Maitland, FL 32751
P (407) 661-9100
F (407) 661-9101
c-p.com

03.04.2022



PANDA EXPRESS
TRUE WARM AND WELCOME 2200
3030 DERITA ROAD
CONCORD, NC 28027

P-500

PLUMBING DETAILS

TRUE WARM & WELCOME 2200 R4