

DOUBLE WALL FACTORY BUILT DUCTWORK

- ALL DUCTWORK IS REQUIRED TO BE INSTALLED WITH THE MAXIMUM SUPPORT SPACING LISTED BELOW.
- FOR A COMPLETE LIST OF APPROVED SUPPORT METHODS, SEE THE ENTIRE INSTALLATION AND OPERATION MANUAL.
- DUCTWORK SHALL SLOPE NOT LESS THAN 1/16" PER LINEAR FOOT TOWARDS THE HOOD OR AN APPROVED GREASE COLLECTION RESERVOIR.
- WHERE HORIZONTAL DUCTS EXCEED 75 FEET IN LENGTH, THE SLOPE SHALL NOT BE LESS THAN 3/16" PER LINEAR FOOT.

VERTICAL			
TYPE	WALL SUPPORT (FT)	CURB SUPPORT (FT)	FLOOR SUPPORT (FT)
2R & 2R HT (5"-16")	20'	24'	24'
2R (18")	18'	24'	24'
3R & 3Z (5"-24")	10'	24'	24'
3Z (26" - 36")	10'	20'	20'

<p>NOTE: UNLESS OTHERWISE STATED, PANDA RESTAURANT GROUP SHALL PROVIDE ALL EQUIPMENT ON THE FOLLOWING CAPTIVEAIRE SHEETS, INCLUDING: HOODS, FIRE SYSTEM, EXHAUST FANS, SUPPLY FAN, MATHEROOM FAN AND ELECTRICAL INTERLOCK PACKAGE</p> <p>DOUBLE WALL DUCT BY MECHANICAL</p> <p>PLEASE USE CONTACT BELOW FOR PRICING</p>	<p>DATE: 12/12/2022</p> <p>DWG.#: 5767460</p> <p>DRAWN BY: AH-86</p> <p>SCALE: 3/4" = 1'-0"</p>
<p><u>ANSUL GAS VALVE:</u></p>	<p>MASTER DRAWING</p>
<p>THE ANSUL GAS VALVE IS PROVIDED BY CAPTIVEAIRE SYSTEMS. CONTACT OUR OFFICE WITH THE VALVE SIZE 3-DAYS IN ADVANCE OF WHEN IT IS NEEDED ON SITE.</p>	
<p>FOR QUESTIONS CALL THE CAPTIVEAIRE SOUTHERN CALIFORNIA OFFICE</p> <p>3002 DOW AVENUE, SUITE 410 TUSTIN, CA 92780</p> <p>TEL: 714-957-1500 EMAIL: REG686CAPTIVEAIRE.COM</p>	<p>SHEET NO.</p> <p>9</p>

www.catholice.com



All ideas, designs, arrangement and plans indicated or represented by this drawing are the property of Panda Express Inc. and were created for use on this specific project. One of these ideas, designs, arrangements or plans may be used by or disclosed to any person, firm, or corporation without the written permission of Panda Express Inc.

REVISIONS

[illegible]

ISSUE DATE

1	95% SUBMITTAL	03/13/2023

DRAWN BY: CM

PANDA PROJECT #

ARCH PROJECT #



PANDA EXPRESS

EXCHANGE FOOD COURT
1386 WASHINGTON BLVD
FT EUSTIS, VA 23604

H-009

HOOD DETAIL PLAN

HOOD DETAIL PLAN
FOR REFERENCE ONLY

BID SET (05/01/2023) NOT FOR CONSTRUCTION