

- 1) COORDINATE AS REQUIRED WITH THE CITY OF FAIRFAX INSPECTIONS DURING CONSTRUCTION FOR REQUIRED INSPECTIONS.
- 2) THIS SITE INDICATES SANITARY SEWER LATERALS. THIS WORK TO BE INSTALLED BY A LICENSED PLUMBER IF STATE LAW REQUIRES. ALL WORK MUST BE INSPECTED THE CITY OF FAIRFAX CODES AND INSPECTION DEPARTMENT.
- 3) ALL ON-SITE PVC PIPE SHALL HAVE CLASS B BEDDING.
- 4) NOTIFY WATER AND SEWER INSPECTOR PRIOR TO START OF CONSTRUCTION.
- 5) THE CONTRACTOR SHALL PROVIDE A COMPLETE SET OF AS-BUILT DRAWINGS INCLUDING ALL RIM ELEVATIONS, INVERT ELEVATIONS, PIPE SIZES, AND PIPE MATERIAL FOR ALL PUBLIC MAINS TO THE ENGINEER AS SOON AS INSTALLATION IS COMPLETE.
- 6) OWNER SHALL BE RESPONSIBLE FOR ANY REPAIR OR REPLACEMENT OF ANY IMPROVEMENTS WITHIN THE SANITARY SEWER, WATER, DRAINAGE, AND SEWAGE(S) DUE TO MAINTENANCE OF SEWER, WATER, STORM DRAIN OF THE CITY OF FAIRFAX.
- 7) CONTRACTOR SHALL INSTALL THE DOWNSTREAM SANITARY SEWER CONNECTION PRIOR TO THE CONSTRUCTION OF THE ON-SITE SERVICE LATERALS. CONTRACTOR SHALL FIELD VERIFY ALL EXISTING UTILITIES SHOWN ON THE PLANS BY POT HOLING THE LINES. THE CONTRACTOR SHALL HAVE THE LINES SURVEYED, INCLUDING HORIZONTAL AND VERTICAL LOCATION, DEPTH, AND SLOPE. THE CONTRACTOR SHALL BE RESPONSIBLE TO DETERMINE IF ANY CITY UTILITIES WILL AFFECT THE CURRENT SANITARY SEWER DESIGN.
- 8) PVC SANITARY SEWER LINE SHALL BE ASTM D 3034, RATED SDR 35 WITH INTEGRALLY MOLDED BENDS, ASTM D 3034, TABLE 2, WITH FACTOR SUPPLIED ELASTOMERIC GASKETS AND LUBRICANT. DIP SANITARY SEWER LINES SHALL BE ASTM A746, CLASS 50 WITH AWWA C111, RUBBER GASKET JOINT DEVICES.
- 9) CONTRACTOR TO POT HOLE EXISTING WATER LINE, UNDERGROUND ELECTRICAL LINES, GAS LINE, UNDERGROUND TELEPHONE, FIBER OPTIC, AND ANY OTHER UTILITY LINES WITHIN THE RIGHT OF WAY DURING DESTRUCTION OF EXISTING LINES AND COORDINATE FIELD LOCATIONS AN DEPTHS OF THESE UTILITIES WITH ENGINEER FOR PROPOSED UTILITY CROSSINGS AND PROPOSED PAVEMENT OVER EXISTING LINES. THESE LINES MAY REQUIRE RELOCATION.
- 10) THE CONTRACTOR SHALL CONSTRUCT ALL SEWER ON THIS PLAN IN ACCORDANCE WITH THE CITY OF FAIRFAX STANDARDS.

